



BRIHANMUMBAI MUNICIPAL CORPORATION
MUMBAI FIRE BRIGADE



FIRE SAFETY COMPLIANCE CERTIFICATE
NURSING HOME

WARD: P/N

APPLICATION NO: 1600020573

This Compliance Certificate is issued with respect to fire safety point of view only .

Name of Nursing Home : M/S. ZENITH HOSPITAL
Address of Nursing Home : PARTH BUSINES PLAZA, MITH CHOWKI, LINK ROAD,
MALAD (WEST), MUMBAI 400064
Name of the Licensee : DR. AMITANAND RAMCHANDRA AJGAONKAR
Registration No. : 0887491146

This is the compliance with respect to previous online issued Fire safety requirements for the above mentioned Nursing home and as per the undertaking cum Indemnity bond submitted by the applicant. During the Inspection, it was noticed that the Fire safety requirements stipulated earlier are complied with. However, if any non-compliance of Fire safety requirements is noticed in the premises after the inspection, then the inspecting officer /approving officer or this department will not be responsible for the same.

However, it is the duty/responsibility of owner/ occupier of the premises to maintain the fire prevention & life safety measures in good repair & efficient condition all the time in accordance with the provisions in Section 3 (1) of Maharashtra Fire Prevention & Life Safety Measures Act. If applicable the certificate in prescribed form (Form-B) from a Licensed Agency shall be submitted twice a year in the months of January & July, regarding the maintenance of Fire safety & life safety measures in accordance with the provisions in Section 3 (3), to the Nominated Officer / Chief Fire Officer.

REMARKS:

- This fire safety compliance certificate is in respect of previous online issued fire safety requirements under Application No. 1600020573 dated 02.09.2022 for the Nursing Home on 1st level part basement (Storage only), ground floor, 1st & 2nd floor of area about 1500.00 sq. mtrs. (Certified by Architect).
- Guideline of NBC (Part IV (4.3 & 4.4.2) and DCPR-2034 regarding occupancy load along with NBC guideline (Part IV (4.2, 4.2.3 & 4.2.4) regarding exits shall be considered for calculating number of beds.
- This compliance certificate issued from fire safety point of view only, without prejudice to legal matters pending in court of law if any & inspection carried out by inspecting officer.
- Authenticity of structure, Addition, Alteration, Change of user, Amalgamation, authorized / unauthorized construction, Encroachment etc. shall be verified by competent Municipal Authorities.
- Compliance of the fire safety measures is for minimizing the chances of occurrence of the fire through active & passive fire safety measures. Any Non-Compliance at any instance may cause occurrence of fire.

PANDURANG Digitally signed by
PANDURANG
GANPATRAO GANPATRAO DUDHAL
Date: 2022.09.14
12:33:44 +05'30'

Inspecting Officer
Mumbai Fire Brigade

Deepak Digitally signed
by Deepak
Kalipada Ghosh
Date: 2022.09.14
15:19:51 +05'30'

Approving Officer
Mumbai Fire Brigade

The verification of Authenticity of structure, Mezzanine floor, Loft, Addition, Alteration, Change of user, Amalgamation, authorized / Unauthorized construction, Encroachment, Area of the premises is not under the purview of this department and will not be responsible for any illegality and its consequences thereof. In case adverse remarks received from A.E. (B&F), then this Compliance Certificate is treated as cancelled.